



BASIS DC PCS - Lead in Water Test Results



FY20 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
BASIS DC PCS	WS-014-001	Food Prep Sink	1	In kitchen		Mid	WF-082019-014001-03	1/10/2020	FT-FY20-082019-014001-A	2.3	FT-FY20-082019-014001-B	<1
BASIS DC PCS	WS-014-002	Cooler	1	In hallway adjacent to kitchen	Low	Right	WF-082019-014002-03	1/10/2020	FT-FY20-082019-014002-A	<1	FT-FY20-082019-014002-B	<1
BASIS DC PCS	WS-014-003	Cooler	1	In hallway adjacent to kitchen	High	Left	WF-082019-014003-03	1/10/2020	FT-FY20-082019-014003-A	<1	FT-FY20-082019-014003-B	<1
BASIS DC PCS	WS-014-006	Cooler	2	In hallway adjacent to boys' and girls' restroom	Low	Right	WF-082019-014006-03	1/10/2020	FT-FY20-082019-014006-A	<1	FT-FY20-082019-014006-B	<1
BASIS DC PCS	WS-014-007	Cooler	2	In hallway adjacent to boys' and girls' restroom	High	Left	WF-082019-014007-03	1/10/2020	FT-FY20-082019-014007-A	<1	FT-FY20-082019-014007-B	<1
BASIS DC PCS	WS-014-008	Break Room	3	In teachers' lounge room 301			WF-082019-014008-03	1/10/2020	FT-FY20-082019-014008-A	<1	FT-FY20-082019-014008-B	<1
BASIS DC PCS	WS-014-009	Cooler	3	In hallway adjacent to boys' and girls' restroom	High	Left	WF-082019-014009-03	1/10/2020	FT-FY20-082019-014009-A	<1	FT-FY20-082019-014009-B	<1
BASIS DC PCS	WS-014-010	Cooler	3	In hallway adjacent to boys' and girls' restroom	Low	Right	WF-082019-014010-03	1/10/2020	FT-FY20-082019-014010-A	<1	FT-FY20-082019-014010-B	<1
BASIS DC PCS	WS-014-011	Cooler	4	In hallway adjacent to boys' and girls' restroom	High	Left	WF-082019-014011-03	1/10/2020	FT-FY20-082019-014011-A	<1	FT-FY20-082019-014011-B	<1
BASIS DC PCS	WS-014-012	Cooler	4	In hallway adjacent to boys' and girls' restroom	Low	Right	WF-082019-014012-03	1/10/2020	FT-FY20-082019-014012-A	<1	FT-FY20-082019-014012-B	<1
BASIS DC PCS	WS-014-013	Break Room	5	In teachers' lounge room 501			WF-082019-014013-03	1/10/2020	FT-FY20-082019-014013-A	<1	FT-FY20-082019-014013-B	<1
BASIS DC PCS	WS-014-014	Cooler	5	In hallway adjacent to boys' and girls' restroom	High	Left	WF-102019-014014-04	1/10/2020	FT-FY20-102019-014014-A	<1	FT-FY20-102019-014014-B	<1
BASIS DC PCS	WS-014-015	Cooler	5	In hallway adjacent to boys' and girls' restroom	Low	Right	WF-102019-014015-04	1/10/2020	FT-FY20-102019-014015-A	<1	FT-FY20-102019-014015-B	<1
BASIS DC PCS	WS-014-016	Cooler	6	In hallway adjacent to room 609	High	Left	WF-102019-014016-04	1/10/2020	FT-FY20-102019-014016-A	<1	FT-FY20-102019-014016-B	<1
BASIS DC PCS	WS-014-017	Cooler	6	In hallway adjacent to room 609	Low	Right	WF-102019-014017-04	1/10/2020	FT-FY20-102019-014017-A	<1	FT-FY20-102019-014017-B	<1